

FACT MATERIALS DEPARTMENT

CORRIGENDUM

TENDER No. MM/172/E26153 Dated 14-09-2022
(Tender ID: 2022_FACT_712425_1)

SUBJECT: Technical Corrigendum-Reg.

Please note the following

	Original	Amended as per this Corrigendum
Technical Procurement Specification No. CDNPELEC2022-2 Clause 4.2 in Page 4 OF 31	The panels shall be constructed from prime quality folded and riveted Aluminum Zinc coated steel sheet or pre-galvanized sheets of 2 mm thickness. Only doors and end covers shall be painted/powder coated with shade as specified. All non-painted steel parts shall be zinc-plated or galvanized.	The panels shall be constructed from prime quality folded and riveted Aluminum Zinc coated steel sheet or pre-galvanized sheets or Powder Coated CRCA sheets of 2 mm thickness. All non-painted steel parts, if any, shall be zinc-plated or galvanized or powder coated.

October 18, 2022

DY. GENERAL MANAGER (MATERIALS)