

**FERTILISERS AND CHEMICALS TRAVANCORE LTD**

CLARIFICATIONS ON QUERIES RAISED BY VENDORS

**Name of Work:** OSBL pipelines for 1650 MTPD NPK plant-piping, mechanical, instrumentation, civil and structural Works, Amablamedu, KOCHI**Tender ID:** 2024\_FACT\_836531\_1**Queries raised by bidders**

SL NO	QUERY DESCRIPTION	CLARIFICATION TO QUERY
1	<p>As per the scope of work and BOQ given it is clear that it is a composite work with piping, civil and instrumentation jobs. Also, we have noticed that the IBR jobs involved in the total scope of work is comparatively small. We have previous experience in composite works but have no IBR license. All the criteria other than IBR certification for the above subjected tender will be qualified by us. So, we hereby request you to waive off the IBR requirement for the subjected tender so that we can also participate in the tender.</p>	<p>The IBR requirement shall be as specified in the Pre-Qualification Criteria (PQC) .</p>
2	<p>The work is inclusive Civil works also. Approximately it may be about 25% of the total quantity of work. But Pre-qualification work order for participation in this bid, is instructed for Mechanical piping works only. As to our opinion pre-qualification may be considered inclusive of "Civil category works" also. So we humbly request the Company to take necessary steps. for pre-qualification criteria, by considering both category of works. ( Civil and Mechanical Work Order).</p>	<p>PQC shall be as specified in the tender .</p>

**FERTILISERS AND CHEMICALS TRAVANCORE LTD**

## CLARIFICATIONS ON QUERIES RAISED BY VENDORS

3	Pressure regulating valves are not within our current manufacturing range; hence, we regret to inform you that we will not be quoting for this tag.	Please take up with alternate vendors for availability of item and quote comprehensively for all items. The bids in which all the items are quoted shall only be considered for evaluation.
4	Positioner Specifications:- Kindly provide detailed specifications, including type, certifications, and requirements for the position transmitter.  Airset Specifications:- Please share detailed specifications, including the drain type and material of construction (MOC).	Specifications are already included in data sheets and tender. (Area classification IEC Zone 2 Gr IIA TI, Suitable positioner shall be supplied, Exd type preferred.)
5	Approved Vendor List for Instrumentation:- We request you to arrange and share the approved vendor list for our review.	Approved vendor list already included in tender. Supply from other vendors will be dealt as per 32687-14-PS-002 SPL(INST) clause 4.1.
6	In Item 417, It is mentioned supply for Integration of OM Water pump and also in Item 418 supply is mentioned. Kindly make it clear that, whether item no. 418 erection is supply against Item no. 417.  Item 419 and 420. Same quarry as above.	Yes. Item 417 is supply scope and 418 is the erection scope for the items listed/ required by item 417.  419 is supply scope and 420 is the erection scope for the items supplied against item 419.
7	Also clarify whether the pump will be provided by FACT for Items 417,419, 40 and 41.	Pumps will be supplied by FACT