

**CORRIGENDUM FOR NEW 10000 MT DOUBLE WALL DOUBLE INTEGRITY AMMONIA STORAGE TANK AND ASSOCIATED FACILITIES FOR FACT-CD, AMBALAMEDU ON LSTK BASIS**

**C. ELECTRICAL**

1. *Document No. 32645-13-DA-92401, Clause No. 4.5. (a)*

*“Type of MCC single front draw out type”*

*The above clause is modified as*

*“Type of MCC double front draw out type”.*