



THE FERTILISERS AND CHEMICALS TRAVANCORE LTD.
(A Govt. of India Enterprises)
CORPORATE MATERIALS

CORRIGENDUM

Sub: EHV Outdoor Current and Voltage Transformers, FACT-UC

- Ref: 1. Enquiry No: MM/175/E21522 (Tender Id: 2020_FACT_558753_1)
2. Technical Procurement Specification(TPS) No: SPEC-FACT-UC-EHV-CT-VT-001

The following clarifications are issued based on queries raised during Pre Bid Meeting conducted on 22.05.2020 at FACT PD Conference Hall, Udyogamandal.

Sl No	TPS Page No	Clause No	Original Clause	Amended Clause
1	Page 3 of 14	1.3	Vendor's scope shall include design, material, manufacture, testing, supply and commissioning supervision of the CTs and VTs, as further described in sections that follow.	Vendor's scope shall include design, material, manufacture, testing, supply and commissioning supervision (if applicable) of the CTs and VTs, as further described in sections that follow.
2	Page 3 of 14	2.1	The vendor shall complete the supply of the CTs and VTs within a period of 12 weeks from date of final drawing review/approval. The drawings for review/approval shall be submitted within 10 days from the date of LOI. Revised final drawings for final approval, after incorporating the all comments/ changes from Purchaser, if any, shall be submitted within 10 days from date of intimation of comments/ changes in drawing from Purchaser.	The vendor shall complete the supply of the CTs and VTs within a period of 16 weeks from date of final drawing review/approval. The drawings for review/approval shall be submitted within 10 days from the date of LOI. Revised final drawings for final approval, after incorporating the all comments/ changes from Purchaser, if any, shall be submitted within 10 days from date of intimation of comments/ changes in drawing from Purchaser.
3	Page 4 of 14	3.4	All necessary accessories including, mounting bolts, nuts and washers etc. Support structure is not in the scope of bidder.	Support structure is not in the scope of bidder. All required accessories shall be supplied as per manufacturer's standard practise.
4	Page 7 of 14	3.23	Primary terminal details : to be supplied with suitable terminal connectors	Primary terminal details: Horizontal and Shall be suitable for connecting 25mm rigid copper pipe conductor. To be supplied with suitable terminal connectors.
5	Page 7 of 14	4.20	Primary terminal details : to be supplied with suitable terminal connectors	Primary terminal details: Horizontal and Shall be suitable for connecting 25mm rigid copper pipe conductor. To be supplied with suitable terminal connectors.