



FERTILISERS AND CHEMICALS TRAVANCORE LTD

CLARIFICATIONS ON QUERIES RAISED BY VENDORS

CORRIGENDUM

NAME OF THE WORK:- Repair And Rehabilitation works of Existing structures For Fact Cochin Division.

Tender_No: 04030/2022-2023/E26472

Tender ID: 2022_FACT_730274_1

	<i>Queries Raised by bidders</i>	<i>FACT Reply</i>
1	Have the repair locations of the SILO shell been identified, if yes, we request FACT to kindly provide us with the details of the areas where the repair works are to be carried out	The repair locations will be evident in thorough Site inspection. Request the bidder to kindly conduct Site visit.
2	We request FACT to kindly share the NDT / Inspection report, so that we will get to know the locations where the respective repair/strengthening activities to be carried out. Also, drawings pertaining to the SILO and the GANTRY is required.	Health Study report will be given on written request for the same as mentioned in tender. General arrangement drawings is enclosed in the tender document. Further detailed drawings will be shared only after award of work.
3	We request FACT to kindly clarify whether the waterproofing is to be done for outer face of the SILO dome shell area i.e., the outer exposed area	Waterproofing is to be done only on the distressed are of the Silo dome shell. Bidder may kindly conduct site visit
4	In the item pertaining to Nozzles, it is stated that nozzles to be drilled and epoxy grouting needs to be carried out, but the nozzle fixing & epoxy grouting are two activities, the rate of epoxy consumption per nozzle is not stated in the BOQ description.	The rate of epoxy consumption may be considered as 300-400 grams per nozzle.
5	In Sl.No. 20.01 pertaining to waterproofing, it is stated that repair activity to be carried out using PMM and then waterproofing needs to be carried out. It is mentioned as composite item but the rate pertaining to repairing/plastering is mentioned separately. Need clarification, whether the item no.20.01, i.e. waterproofing is a composite item or the payment for repair will gets paid separately.	Item no 20.01 payment will be for repair and waterproofing as a composite item.
6	We request FACT to kindly confirm if FACT shall provide the water and the power free of cost?	Confirmed that water and power will be provided free of cost