



Name of Work: Discharging, Washing, Recharging of HADSA reactor Packing Material and associated cleaning in HYAM Plant- PD during ATA 2022

Queries raised by bidders

SL NO	QUERY DESCRIPTION	CLARIFICATION TO QUERY
1	Kindly confirm how much days advance notice/mobilization period will be given?	Two weeks of mobilization period shall be given.
2	What are the PPEs to be considered as per FACT philosophy & guidelines?	Basic PPEs such as cotton coverall, helmet, safety shoes, gloves & safety goggle & face mask (covid 19) is sufficient
3	Kindly confirm whether only water spraying arrangements by laying tarpaulins on your concrete floor and spraying using your provided water at 4kg without any external pressure booster pump is sufficient.	Sufficient and the water at 4.0 kg/cm ² can be taken from our hose station
4	FACT charges for providing crane and forklift?	Crane shall be supplied by contractor. Fork lift can be provided , if required, free of cost, subject to availability,