



27.10.2025

Name of Work : Laying of 3 X 400 Sq.mm power cable from 110 kV Substation to Water Treatment Plant in FACT-UC.
E-Tender ID No : 2025_FACT_880233_1

Corrigendum(Technical)

Programme of Work (SCH-B) and **Special Conditions of Contract (SCH-Q1)** have been revised as attached.

All other Terms and conditions of the tender shall remain unchanged.

Amrutha Terence
Officer(Des)Mat-C

	FACT CORPORATE MATERIALS CONTRACTS	Tender No. 03017/2025-2026/E32257
<u>PROGRAMME OF WORK</u>		SCHEDULE - B
		PAGE 1 OF 1

Name of Work: Laying of 3 X 400 Sq.mm power cable from 110 kV Substation to Water Treatment Plant in FACT-UC.

The contract shall remain valid for a period of **12 months** from the date of issuance of the Work Order. For the fast execution of work, the period of completion is divided into two phases namely Excavation of Cable trench and Laying of Power and OFC cables. There will be two separate start date and completion period for two phases of work.

Period of Completion for Phase-1: The period of completion for phase-1 [ie excavation of cable trench] will be **three months**. The zero date mentioned in the work-to-proceed notice shall be considered as the start date for phase-1. The cable trench excavation for the entire length, including horizontal drilling if required, shall be completed within the three months period.

Period of Completion for Phase-2: The period of completion for phase-2 [ie Cable laying and all other works in this contract] will also be **three months**. Separate clearance date will be issued for Phase-2 work and the entire work mentioned in this contract shall be completed within three months from this clearance date.

 FACT	FACT CORPORATE MATERIALS - CONTRACTS	Tender No. 03017/2025-2026/E32257
<u>SPECIAL REQUIREMENTS OF THE CONTRACT</u>		Page 1 of 2
		SCHEDULE - Q1

Name of Work:- Laying of 3 X 400 Sq.mm power cable from 110 kV Substation to Water Treatment Plant in FACT-UC.

This 'Special Requirements of Contract' form part of the contract and is to be read in conjunction with the Proforma conditions of contract. Wherever the provisions under Special Requirements of Contract are in conflict with any of the provisions under other conditions, provisions in the Special Requirements of Contract shall prevail.

1. The purpose of this contract is to lay 3 x 400 sq.mm power and OFC cable from 110 kV Substation to Water Treatment plant of FACT-UC. The scope of work also includes excavation of cable trench, providing straight joint and end termination of power cables, providing concrete protective tiles over the laid cable, providing cable joint protection chambers etc.
2. The validity of this contract shall be **12 months** from the date of issue of work order.
3. The material shall be handled carefully without causing any damage to the material.
4. The service of horizontal directional drilling machine is optional. The area in which drilling machine service is required will be finalized by the Engineer in Charge as and when required.
5. Excavation for trench work must be carried out with utmost care due to the presence of existing underground cables and water pipe line, along the entire route. To avoid damage to these cables/ pipe lines, manual excavation is preferred. Any damage to these existing cables/ pipe lines will result in penal charge to the contractor for material loss and subsequent production loss, if any.
6. It is advised to use suitable HDPE sleeves while joining the HDPE pipes. This is an optional item and will be required in special areas where trench excavation cannot be possible and to be executed as per instruction of the Engineer-in- Charge.
7. The reinforcement of concrete tiles should be accomplished with 8 mm TMT steel bars, utilizing four bars in width and three bars in length.
8. The contractor shall arrange continuous supervision for the excavation work to avoid the risk of damaging the existing underground electric cables, telephone cables, water pipe lines etc.
9. **Period of completion:** For the fast execution of work, the period of completion is divided into two phases namely Excavation of Cable trench and Laying of Power and OFC cables. There will be two separate start date and completion period for two phases of work.

 FACT	FACT CORPORATE MATERIALS - CONTRACTS	Tender No. 03017/2025-2026/E32257
<u>SPECIAL REQUIREMENTS OF THE CONTRACT</u>		Page 2 of 2
		SCHEDULE - Q1

Period of Completion for Phase-1: The period of completion for phase-1 [ie excavation of cable trench] will be three months. The zero date mentioned in the work-to-proceed notice shall be considered as the start date for phase-1. The cable trench excavation for the entire length, including horizontal drilling if required, shall be completed within the three months period.

Period of Completion for Phase-2: The period of completion for phase-2 [ie Cable laying and all other works in this contract] will also be three months. Separate clearance date will be issued for Phase-2 work and the entire work mentioned in this contract shall be completed within three months from this clearance date.

Liquidated damages: The liquidated damages at the rate of ½% (half percent) of the contract value per day subject to a maximum of 7½% (seven & a half percent) of the contract value will be realized from the contractor in case of delay in Phase-1, Phase-2 or both.

10. The work should be carried out as per the instructions of the Engineer-in-Charge or the person appointed by him.

11. Contractor shall produce the muster rolls of the workmen engaged by them, to township electrical office in every day.

The contractor shall pay wages to workers through banks. Proof of the bank remittance certified by banks should be submitted along with the wage roll to the FACT township electrical department before the 5th of every month.

The contractor shall be responsible for all statutory/ obligations towards their employees and also for their wages, PF benefits, etc. during the course of the contract period. The contractor shall maintain all records as per statutes. Bills shall be cleared for payment only after fulfilling these conditions to our satisfaction.

12. The Contractor shall take delivery of the materials supplied by the Company from the General Stores/ Electrical Office or elsewhere and transport to the work site at their cost.

13. The materials unloaded for the purpose of cable protection like river sand/M-sand/quarry dust, solid bricks etc. shall be listed in township electrical office by the concerned driver of Vehicle as and when they are unloaded.

14. Any work connected with the electrical cables / installations shall be done only after getting specific clearance from the Electrical Supervisor concerned.

15. The decision of SMM (E) SS&TS with regard to the workmanship and progress of the work shall be binding on the Contractor.

16. The work site shall be cleaned properly after each day's work as instructed by Site Engineer.

 FACT	FACT CORPORATE MATERIALS - CONTRACTS	Tender No. 03017/2025-2026/E32257
<u>SPECIAL REQUIREMENTS OF THE CONTRACT</u>		Page 3 of 2
		SCHEDULE - Q1

17. We are a Company having Environmental Management System according to ISO 14001 standard. The Contractor shall ensure that none of their activities against the standard.
18. The quantity given in the schedule of work is only an approximate indication and may vary depend upon the actual requirement at the time of execution. FACT reserves the right to reduce or increase the quantity at any time without assigning any reason whatsoever and does not give any guarantee regarding the quantity. The contractor has no right to claim loss or loss of profit due to variations in the quantity of work made available for execution. During the contract period, if the quantity exceeds for any of the item, it can be re-appropriated without exceeding the total contract value.
19. Cable laying shall be as per the Annexure-1. The 3.3 KV cable intended to lay is of one kilometer length in single drum. Hence sufficient numbers of cable rollers for un-reeling the cable shall be arranged by the contractor to enable trouble free laying of the cable.
20. Any further details can be obtained from the SMM (E) SS&TS during office hours.
21. The general terms and conditions of the contract of FACT shall also be applicable to this contract.